



## EC DECLARATION OF CONFORMITY

The manufacturer **LAE electronic Srl**, registered offices at *via Padova, 25 Oderzo ITALY*, on the basis of the test results obtained using appropriate standards, states that the following product:

Name: thermometer  
Model(s): **LTS12PT(.)**  
Version(s): ..E, U, I, D

meets the essential requirements provided by:

### **Low Voltage Directive EEC 73/23 - 93/68** **EMC Directive EEC 89/336 - 93/68 - 93/97**

Standards and levels used:

	EN60730-1; EN60730-2-9	
<b>EN50081-1:</b>		
Emissions	EN55022	class B
<b>EN50082-1:</b>		
Electrostatic Discharge	EN61000-4-2 / IEC1000-4-2	- LEVEL IV
RF EM Field	EN61000-4-3 / IEC1000-4-3	- LEVEL II
Fast Transients	EN61000-4-4 / IEC1000-4-4	- LEVEL IV
Surges	EN61000-4-5 / IEC1000-4-5	- LEVEL III
RF Common Mode	EN61000-4-6 / IEC1000-4-6	- LEVEL II
Voltage Dips/Interruptions	EN61000-4-11 / IEC1000-4-11	

Oderzo, 18/10/2000

*Franco Perissinotto*  
Test Department